

Certificate



for European Product Safety

Reference No. 1806800

Conduit for electrical installations

Type designation TAM 16, TAM 20, TAM 25

Certificate holder **PIPELIFE FINLAND OY**
Mustikkakankaantie 1
FI-91600 Utajärvi
FINLAND

The product complies with the standard(s) EN 61386-1:2008
EN 61386-22:2004+A11

Date of expiry 26 January 2023

EU Directive information According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Bo Berglöf

Date 13 February 2018

Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

**Intertek
Appendix***Reference No. 1806800**Technical data*

Type designation	TAM 16, TAM 20, TAM 25
Sizes	16, 20 and 25 mm, corrugated conduit
Classification	3341
Temperature range	-25/+60°C

Manufacturing site(s)	PIPELIFE FINLAND OY Mustikkakankaantie 1 FI-91600 Utajärvi FINLAND
-----------------------	---

This certificate is based on a certificate with ref. No. NCS/FI 30315 dated 26 January 2018, issued by SGS Fimko according to the Nordic Certification Service Agreement.

This certificate replaces previously issued ref. No. 1303895 dated 27 March 2013.
A new certificate has been issued on account of new testing.

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed
Bo Berglöv*Date* 13 February 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.