

## CERTIFICATE NCS/FI 30315



Our Ref. 290153-2

**Product** Installation conduit, pliable

**Type** TAM 16  
TAM 20  
TAM 25

**Trade mark** PIPELIFE

**Certificate Holder/  
Manufacturer** Pipelife Finland Oy  
Mustikkakankaantie 1  
FI-91600 UTAJÄRVI  
FINLAND

**Technical information** Sizes 16, 20 and 25 mm, corrugated conduit  
Classification 3341  
Temperature range -25 / +60°C

**The product is certified  
according to the following  
standard(s)** EN 61386-1:2008  
EN 61386-22:2004 + A11:2010

**Validity** This certificate is valid until 26 January 2023 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

**Directive information** The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Date of issue** 26 January 2018

**SGS Fimko Ltd**

**Signature**

  
Sixten Lökfors  
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkinielementie 3 P.O.Box 30 FI-00211 Helsinki, Finland  
t. +358 9 696 361 f. +358 9 692 5474 [www.sgs.fi](http://www.sgs.fi)

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Appendix to Certificate: 30315

**Manufacturing site(s)**

Pipelife Finland Oy  
Mustikkakankaantie 1  
FI-91600 UTAJÄRVI  
FINLAND

**Additional information**

This certificate replaces certificate NCS/FI 27899 dated 14 February 2013, due to new testing.

