



LICENCE OF CERTIFICATION

Date of valid edition
2013-02-18

No:
5106

Date of issue
2011-08-24

Reference

Licensee's name and address

Conformity mark covered by license

Fusion Group Ltd
Fusion House, Smeckley Wood Close
Chesterfield Trading Estate, Chesterfield S41 9PZ Derbyshire
Great Britain



Information regarding licensee/manufacture

Licensee's technical officer Lisa Shelton	Telephone +44 1246 26 26 07	Telefax +44 1246 26 26 06
	E-mail lshelton@fusiongroup.com	
Manufacturer Fusion Group Ltd	Place of manufacture Smeckley Wood Close, Chesterfield Trading Estate Chesterfield S41 9PZ Derbyshire Great Britain	

Product covered by the licence

Type of product Plastics piping systems for water supply, and for drainage and sewer under pressure – Polyethylene (PE)	Standard Normative document EN 12201:2011	Specific rules INSTA SBC EN 12201									
Specification of product Electrofusion fittings made from PE100											
<table><tr><td>SDR class</td><td>11</td><td>17</td></tr><tr><td>Nominal outside diameter</td><td>16 - 225 mm</td><td>63 - 225 mm</td></tr><tr><td>Size group</td><td>1, 2</td><td>1, 2</td></tr></table>			SDR class	11	17	Nominal outside diameter	16 - 225 mm	63 - 225 mm	Size group	1, 2	1, 2
SDR class	11	17									
Nominal outside diameter	16 - 225 mm	63 - 225 mm									
Size group	1, 2	1, 2									
Confidential information according to the enclosure											

The licensee above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certification licence is valid on the condition that the licensee complies with the "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The licensee is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the licensee. This also applies to defective or faulty products.

The licence is valid for one calendar year, unless the licensee or member of INSTA-CERT gives at least three months' notice to the contrary. The licence will be re-issued with an amended "date of valid edition" only if the content and/or conditions of the licence have been changed.

The licence is not transferable.

MEMBER OF INSTA-CERT

SP Sveriges Tekniska Forskningsinstitut

Lennart Månsson



LICENCE OF CERTIFICATION

Confidential appendix 1

Date of valid edition
2013-02-18

No:
5106

Date of issue
2011-08-24

Reference

The tables below shows the approved combinations of sizes, SDR classes and raw materials.

Electrofusion fittings made from PE100

SDR class	11	17
Nominal outside diameter	16 - 225 mm	63 - 225 mm
Size group	1, 2	1, 2

Borealis BorSafe™HE3490-IM, INEOS Eltex® TUB121, Finathene XS10 B