

# Certificate



Intertek

for European Product Safety

Reference No. 1908359

## Conduit for electrical installations

*Type designation* Inflex dim 16mm, Inflex dim 20mm

*Certificate holder* **PIPELIFE SVERIGE AB**  
**Produktion Ölsremma**  
**51484 Ölsremma**  
**SWEDEN**

*The product complies with the standard(s)* EN 61386-1:2008  
EN 61386-22:2004 + A11

*Date of expiry* 30 April 2024

*EU Directive information* According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

*Certification Body* Intertek, Semko AB, Product Certification

*Place* Kista - Stockholm

*Signed*

  
Henrik Wikström

*Date* 30 April 2019

Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

**Intertek**  
**Appendix**

Reference No. 1908359

*Technical data*

|                              |   |
|------------------------------|---|
| <i>Type designation</i>      | Inflex dim 16mm, Inflex dim 20mm  |
| <i>Classification coding</i> | 3342 3267 --10  |
| <i>Trade mark</i>            | PIPELIFE  |
| <i>Product information</i>   | Non-flame propagating corrugated conduits of grey insulating material with size 16mm and size 20mm.<br><br>Temperature range: -25°C / +90°C.<br>Resistance to impact: 2J.<br>Resistance to compression: 750N. |

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

|                              |  |              |                   |
|------------------------------|--|--------------|-------------------|
| <i>Manufacturing site(s)</i> | PIPELIFE SVERIGE AB<br>Produktion Ölsremma<br>51484 Ölsremma<br>SWEDEN                                 |              |                   |
| <i>Certification Body</i>    | Intertek Semko AB, Product Certification   | <i>Place</i> | Kista - Stockholm |
| <i>Signed</i>                | <br>Henrik Wikström | <i>Date</i>  | 30 April 2019     |

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*